

Ref: Qtex/2017/4642/T

Temperature Level Monitoring Report



Client's Name : Dekko Accessories Limited
Client's Address : Singair Road, Hemayetpur, Savar, Dhaka, Bangladesh.
Inspection Date : April 08, 2017
Reporting Date : April 10, 2017

Environmental Condition:

Ambient Temperature : 32.5°C
Relative Humidity : 77 % RH
Weather Condition : Normal

Description of Inspection:

The Temperature level inspection has been done in every sections of the factory. The whole inspection has conducted following the instruction stated in the Qtex Work Instruction **WI-04**. Qtex Assessor Mr. Kanchan Kumar Das has performed the inspection.

Inspection Method:

Temperature Level is measured in °C by semiconductor sensor based instrument. Ambient Temperature is measured by changes in electrical resistance due to heat, which is shown in Celsius. The inspection has been carried out according to the Standard Operating Procedure **SOP-10**.

Instrument's Specifications:

Instrument Name : Hygro-Thermometer
Measuring Range : 0.0 °C ~ 50.0°C and -32.0 °F ~122.0 °F
Resolution : 0.1 °C

TECHNICAL OFFICE:

13, Outer Circular Road
Rajarbagh, Dhaka-1217, Bangladesh.
Contact: +8801799070111
+8802 9333673

CORPORATE OFFICE:

Plot: 07 (Level 5), Raod: 14
Sector: 01, Uttara Model Town
Uttara, Dhaka-1230, Bangladesh.
Contact: +8801989600400
+88 02 8933536

Ref: Qtex/2017/4642/T

Inspection Result:



Inspection Time & Duration: The Inspection has been done between 2.00 PM to 6.10 PM

Sl No.	Name of Sections	Approximate area of sections (sft)	Location of Sections	Measured Temperature in (°C)	Comparative Standard (°C)
1	Casting Section	8000	Button Building, Ground Floor	33.2	<p>Optimum Range: Between 20°C and 26 °C Depending on the time of year and clothing worn.</p> <p>(According to the Compliance Code for Workplace amenities and work environment)</p>
2	Button, Poly & Turning Section	8450	Button Building, Ground Floor	32.5	
3	Button (Leaser) & Packaging Section	5625	Button Building, 1 st Floor	32.6	
4	HTL & PL Section	6790	Button Building, 2 nd Floor	31.6	
5	CD-74 Room	1770	6 Storied Building, Ground Floor	31.6	
6	P.P.I Section	12000	6 Storied Building, 1 st Floor	30.9	
7	QC Lab Room	1000	6 Storied Building, 1 st Floor	28.7	
8	Poly Unit	7645	6 Storied Building, 2 nd Floor	31.7	
9	Screen Printing Unit	5000	6 Storied Building, 5 th Floor	32.2	
10	Offset Printing Section	8000	New Building, Ground Floor	27.5	
11	Poly Unit	11000	New Building, Ground Floor	28.0	
12	Woven Label Production Section	11000	New Building, Ground Floor	26.7	
13	Woven Label Folding Section	8000	New Building, Mezzanine Floor	27.9	
14	Offset Printing Unit	15000	New Building, 1 st Floor	29.6	
15	Poly Unit	15000	New Building, 1 st Floor	30.5	
16	HTL & PL Section	30000	New Building, 2 nd Floor	30.9	

TECHNICAL OFFICE:

13, Outer Circular Road
Rajarbagh, Dhaka-1217, Bangladesh.
Contact: +8801799070111
+8802 9333673

CERTIFIED BY



CORPORATE OFFICE:

Plot: 07 (Level 5), Raod: 14
Sector: 01, Uttara Model Town
Uttara, Dhaka-1230, Bangladesh.
Contact: +8801989600400
+88 02 8933536